

City of Hibernation Section 504 Self-Evaluation and Transition Plan

Adopted December 5, 2014

Hibernation City Hall

Facility	ADA Compliant	Comments/Modifications Needed	Target Completion Date	Person Responsible
Parking Area	Y	Two handicapped spots, properly marked.		
Walkways	Y			
Building Entrances	Y	Main entrance to City Hall has compliant ramp and doors. Side entrance does not have a ramp.		
Interior Doors	N	Door into the Clerk's Office has raised threshold that must be removed for easy access.	4/15/2015	City Manager
Central Hallways	Y			
Meeting Rooms	Y	All meeting rooms on the first floor are compliant, all public meetings will be held on the first floor.		
Utility Payment Office	Y			
Clerk's Office	Y			
Restrooms	N	Stalls in the first floor restrooms are too small for person in wheelchair. Grab bars are installed at the wrong height.	10/30/2015	City Manager
Elevator	Y			
Water Fountain	Y			

Hibernation Community Center

Facility	ADA Compliant	Comments/Modifications Needed	Target Completion Date	Person Responsible
Parking Area	N	Sign is missing from one of the handicapped spots.	2/13/2015	Road Superintendent
Walkways	Y			
Exterior Doors	Y			
Interior Doors	Y			
Meeting Rooms	Y			
Restrooms	N	Faucet in men's room is not compliant.	3/13/2015	Center Director
Director's Office	Y			
Library Area	N	Some aisles are too narrow for wheelchair operation.	6/30/2015	Center Director
Water Fountain	Y			

Black Bear Park

Facility	ADA Compliant	Comments/Modifications Needed	Target Completion Date	Person Responsible
Parking Area	N	No handicapped spots, lot is unpaved.	12/11/2015	Park Superintendent
Walkways	N	Walkways are all wood chips, paved walks needed from parking lot to picnic area and ball field.	5/13/2016	Park Superintendent
Park Office/Restrooms	Y			
Ball Field	N	Paved area needed by stands for wheelchair occupants to watch games.	5/13/2016	Park Superintendent
Picnic Area	Y			
Splash Park	Y			